

Selection of energy efficient air filters for general ventilation – ISO16890



Mr Utkarsh Vardhan
Key Account Manager
Camfil

Energy use



How much money does one save..



to change a light bulb?

How much money does one can
save..


to change to a sustainable air filter?

Did you know?

- HVAC system accounts for approx. 60~70% of the energy used in commercial buildings
- Filter is the most inexpensive part of the HVAC system to improve
- In HVAC, filters stand 2nd when it comes to contributing air flow resistance and hence the pressure drops and hence the energy costs



TCO – Total Cost of Ownership



Life Cycle Cost – Case Study: Conventional Filters v/s ISO16890 Rated Energy Efficient Filters

Formula

$$\text{Energy Cost } \$ (E) = (Q * \Delta P * T) / (\eta * C_o) P_o$$

Q = Airflow (m³/s)

Δp = Average Resistance Over Alloted Time (Pa)

T = Total Operating Time (Hours)

η = Estimated Fan Efficiency

C_o = Horse Power Conversion Constant

Assumptions

1 AHU for 5 years (24/365)

Airflow 16.000 cfm

90% return air

ODA 3 / SUP2

Fan efficiency 80%

SUMMARY



INR 1.13m
Saved



27% CO₂
Reduced



5.60 m³
Waste saved



27%
Lower TCO

COST ANALYSIS



INR 1.13m
Savings over 5 Year(s)
22,720,860
That can be added additional per year

CO₂ ANALYSIS

Difference 31.93 Ton



Camfil Existing

Conventional

ENERGY SAVINGS



Camfil Existing

Conventional

ENVIRONMENTAL IMPACT



31.93 ton of CO₂
saved



53 MWh energy
saved



5.60 m³ waste
saved



12K liters of diesel
Consumed by a passenger car.



5 homes
Average yearly energy use.



34 trash cans
Full of waste diversion saved.

Note!

- Smart filter design can reduce pressure drop without compromising filtration efficiency by as much as 75%
- The more dirt an air filter can capture and hold while maintaining a lower pressure drop means the speed of the fan can remain lower while still providing the required airflow to maintain comfort.
- Energy efficient air filters save significant amount of energy and money!

Eurovent Recommendation 4/23




- Recommendation for the selection of ISO 16890 rated air filters for general ventilation applications
- Developed in a joint effort by the participants of the Eurovent Product Group 'Air Filters'
- Published on 09 January 2018
- Updated in January 2022

Particulate Matter – the smaller, the worse

<https://eurovent.eu/?q=content/eurovent-423-2022-selection-en-iso-16890-rated-air-filter-classes-fourth-edition-english>

PM ₁₀	PM _{2,5}	PM ₁
Particles 10 µm in diameter or smaller can reach the respiratory ducts and potentially cause decreased lung function.	Particles 2.5 µm in diameter or smaller can penetrate the lungs and cause decreased lung function, skin and eye problems.	Particles 1 µm in diameter or smaller are most dangerous. They are tiny enough to enter the bloodstream and lead to cancer, cardiovascular diseases and dementia.



© Camfil AB

1.1.2 BURDEN OF DISEASES

Conducted researches determined an impact of IAQ on the burden of diseases (BoD). The burden of diseases is measured by the means of a so-called disability-adjusted-life-year (DALY). This time-based measure combines years of life lost due to premature mortality and years of life lived in states of less than full health and was originally developed in 1990.

The total estimated burden of disease attributable to IAQ in the European Union is approx. 2m DALYs per year, which means that two million years of healthy life is lost annually. It is worth noticing that, according to latest estimation carried out by French economists, the cost of 1 DALY can amount up to 100.000 EUR. On a global scale, losses resulting from an inadequate IAQ are large.

Step 1 – Outdoor Air

- Selection of local outdoor air quality based on particulate matter levels acc. latest WHO Air Quality Guidelines
 - PM2.5 (particulate matter < 2.5 µm)
 - PM10 (particulate matter < 10 µm)
- **ODA 1** = below WHO limits
- **ODA 2** = less than 50% above WHO limits
- **ODA 3** = more than 50% above WHO limits
- **India = ODA 3**

Category	Description	Typical environment
ODA 1	<p>OUTDOOR AIR, WHICH MAY BE ONLY TEMPORARILY DUSTY</p> <p>Applies where the World Health Organisation WHO (2021) guidelines are fulfilled (annual mean for $PM_{2.5} \leq 5 \mu g/m^3$ and $PM_{10} \leq 15 \mu g/m^3$).</p>	
ODA 2	<p>OUTDOOR AIR WITH HIGH CONCENTRATIONS OF PARTICULATE MATTER</p> <p>Applies where PM concentrations exceed the WHO guidelines by a factor of up to 1,5 (annual mean for $PM_{2.5} \leq 7,5 \mu g/m^3$ and $PM_{10} \leq 22,5 \mu g/m^3$).</p>	
ODA 3	<p>OUTDOOR AIR WITH VERY HIGH CONCENTRATIONS OF PARTICULATE MATTER</p> <p>Applies where PM concentrations exceed the WHO guidelines by a factor of greater than 1,5 (annual mean for $PM_{2.5} > 7,5 \mu g/m^3$ and $PM_{10} > 22,5 \mu g/m^3$).</p>	

Table 1: Outdoor air categories

Step 2 – Required supply air quality

CATEGORY	GENERAL VENTILATION		CATEGORY	INDUSTRIAL VENTILATION	
SUP 1			SUP 1	Applications with high hygienic demands. Examples: Hospitals, pharmaceuticals, electronic and optical industry, supply air to clean rooms.	
SUP 2	Rooms for permanent occupation. Examples: Kindergartens, offices, hotels, residential buildings, meeting rooms, exhibition halls, conference halls, theaters, cinemas, concert halls.		SUP 2	Applications with medium hygienic demands. Examples: Food and beverage production.	
SUP 3	Rooms with temporary occupation. Examples: Storage, shopping centers, washing rooms, server rooms, copier rooms.		SUP 3	Applications with basic hygienic demands. Examples: Food and beverages production with a basic hygienic demand.	
SUP 4	Rooms with short-term occupation. Examples: restrooms, storage rooms stairways.		SUP 4	Applications without hygienic demands. Examples: General production areas in the automotive industry.	
SUP 5	Rooms without occupation. Examples: Garbage room, data centers, underground car parks.		SUP 5	Production areas of the heavy industry. Examples: Steel mill, smelters, welding plants.	


Table 4: General ventilation - indicative examples of application matched to corresponding SUP categories

Table 4: Industrial ventilation - indicative examples of application matched to corresponding SUP categories

Step 3 – Selection

Outdoor air quality		Supply air quality				
		SUP 1	SUP 2	SUP 3	SUP 4	SUP 5
ODA 1	Example 1	ePM10 50% + ePM1 60%	ePM1 50%	ePM2,5 50%	ePM10 50%	ePM10 50%
	Example 2	ePM1 70%	-	-	-	-
ODA 2	Example 1	ePM1 50% + ePM1 60%	ePM10 50% + ePM1 60%	ePM1 50%	ePM2,5 50%	ePM10 50%
	Example 2	ePM1 80%	ePM1 70%	ePM2,5 70%	ePM10 80%	-
ODA 3	Example 1	ePM1 50% + ePM1 80%	ePM1 50% + ePM1 60%	ePM10 50% + ePM1 60%	ePM1 50%	ePM2,5 50%
	Example 2	ePM1 90%	ePM1 80%	ePM2,5 80%	ePM10 90%	ePM10 80%

Table 7: examples of filter classes meeting respective ODA/SUP categories requirements



ePM10 55%



ePM1 80%

Example – Multi stage filtration

Office in Gurgaon: ODA 3 & SUP 2 = min. ePM1 80%



Stage 1
ePM1 60%



Stage 2
ePM1 60%

$$ePM1_{cum} = 100 \times \left(1 - \left(1 - \frac{60}{100} \right) \times \left(1 - \frac{60}{100} \right) \right) = 84\%$$

Summary

- Significance of Filters in Air Handling Units and its contribution to Energy Consumption
- TCO/LCC- a more holistic view on selection of filters, taking in consideration energy efficiency and sustainability.
- Selecting ePM1 filters will result in improved air quality and lower health risk
- Eurovent 4/23 merges theoretical and practical aspects of designing Indoor Air Quality in terms of air filtration
- Eurovent 4/23 provides hands on and effective advice for HVAC planners and manufactures of ventilation equipment to correctly design filtration

“Energy waste elimination is the most green energy one can buy!!”

THANK YOU

Mr Utkarsh Vardhan
Key Account Manager
Camfil